



Date Submitted: 6/21/2016

Water Use Efficiency Annual Performance Report - 2015

WS Name: OCEAN SHORES WATER DEPT

Water System ID# : 63008

WS County: GRAYS HARBOR

Report submitted by: *Matthew Tobert*

Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *01/01/2015* To *12/31/2015*

Incomplete or missing data for the year? *No*

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	<i>258,326,000</i> gallons
Authorized Consumption (AC) – Annual Volume	<i>221,200,000</i> gallons
Distribution System Leakage – Annual Volume TP – AC	<i>37,126,000</i> gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	<i>14.4 %</i>
3-year annual average	<i>9.8 %</i>

Goal-Setting Information:

Date of Most Recent Public Forum: _____ Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

We would like to reduce our usage by 5% over the next five years

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

Do not mail, fax, or email this report to DOH